

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF TRIMBLE COUNTY WATER)
DISTRICT NO. 1 FOR A DEVIATION FROM 807 KAR) CASE NO. 96-354
5:066, SECTION 4(4), REGARDING WATER STORAGE)

O R D E R

By application received July 23, 1996, Trimble County Water District No. 1 ("Trimble Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which requires that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Trimble Water states that its average daily water usage in April 1996, including unaccounted-for water, was approximately 271,000 gallons, and its current water storage capacity is 263,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Trimble Water is not in compliance with Commission Regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Trimble Water should be given until January 1, 2002 to comply with 807 KAR 5:066, Section 4(4).


IT IS THEREFORE ORDERED that:


1. Trimble Water is hereby given until January 1, 2002 to comply with the provisions of 807 KAR 5:066, Section 4(4).


2. Trimble Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2002.

Done at Frankfort, Kentucky, this 23rd day of August, 1996.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director